

April 18, 2017
Dansville Schools
Roof Replacement
Dansville, MI

ADDENDUM NO. 1

NOTICE TO BIDDERS:

This Addendum modifies the original Contract Documents and Project Manual dated March 30, 2017. Bidders must acknowledge receipt of the Addendum on the Bid Form.

Unless otherwise indicated, the work described herein shall comply with, and be equal in all respects to, the original Contract Specifications and Drawings. Include all incidental work required to properly complete the work whether stated herein or not.

QUESTIONS BY CONTRACTORS:

1. None (remove section if not used)

SPECIFICATIONS:

1. Rubbergard EPDM Adhered Roofing System
 - a. Provide .060 WHITE Ultraply TPO, Fully Adhered or Self Adhered roof membrane in lieu of EPDM on Sections 1, 2, and 4.
 - b. Provide .060 TAN Ultraply TPO, Fully Adhered roof membrane in lieu of EPDM on Section 3.
 - c. Flashings and detail to be Ultraply TPO of same color as membrane.

DRAWINGS:

1. None (remove section if not used)

END OF ADDENDUM NO. 1